



No:-


Date:-

BUILDING FITNESS CERTIFICATE

(As per National Building Code of India 2016)

01	Name of Building	: Swami Vivekanand International Public School, Terdal
02	Address	: CTS NO: 1247/1522 of Terdal Town, Terdal Taluk of Bagalkot District
03	Occupancy Classification (NBC 2016)	: Institutional (Educational Building)
04	Year of Construction	: 2004-2005
05	No. of Floors	: G+2 =03
06	Owner	: Chairman Swami Vivekanand International Public School, Terdal
07	Structural System :	: RCC
08	Date of Inspection	: Saturday, December 27, 2025
09	Period of Fitness upto	: Tuesday, December 26, 2028
10	Condition Assessment	: NDT Tests & Visual Assessment
	Component	Condition
	a. Foundation & Basement	: (Satisfactory / Distress) Satisfactory
	b. Columns / Load Bearing Walls	: (Satisfactory / Cracks) Satisfactory
	c. Beams	: (Satisfactory / Cracks) Satisfactory
	d. Slab / Roof	: (Satisfactory / Leakage) Terrace Waterproofing is must.
	e. Staircase	: (Satisfactory/Not satisfactory) Satisfactory
	f. Walls & Plaster Cracks & Condition	: (Minor /Major /None) Minor Cracks to be repaired
	g. Doors & Windows	: (Serviceable/Unserviceable) Serviceable
	h. Flooring	: (Good/Not Good) Good
	i. Parapet / Railing	: (Safe /Unsafe) Safe
11	Major structural defects affecting stability	: Nil / YES Nil
12	Maintenance condition :	: Adequate / Needs improvement Adequate


Remarks:- The structure is in satisfactory and stable condition with no major structural defects. Observed dampness and minor wall cracks are non-structural and repairable. But those cracks to be attended and also waterproofing is must at terrace. The building is safe and fit for occupancy for the intended use.


Sarvashri Consultants Pvt Ltd
Opp Mini Vidhan Soudha,
Kudchi Road, Jamkhandi-587301

CERTIFICATE


Section Officer

The building was inspected on the above-mentioned date, Non-Destructive Testing (NDT) and condition assessment were carried out by the appointed technical consultants. Based on the visual inspection, NDT results, and structural condition assessment reports submitted by the consultants, the structure is found to be structurally sound and safe for its intended occupancy, in accordance with the intent of the National Building Code of India (NBC) 2016, subject to routine maintenance and for the period stated.


Assistant Executive Engineer
PWD Sub-Division, Jamkhandi